

June 2, 2004

DEL ZOTTO PRODUCTS INC
DUANE PIONK
1900 COUNTY RD.1
WRENSHALL MN 55797

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DEL ZOTTO PRODUCTS INC
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP OR HOLDING
Model Number(s): 1650 GAL-2 COMPARTMENT (1089/642)
(42.5" L.L., 25.6/15.1 GAL/IN., 48" MAX. DEPTH OF BURY, 829 G.P.D. WHEN USED AS A
SEPTIC/SEPTIC TANK OR 522 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED
ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20040277

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - WDZ Gasket System by Del Zotto Products Corp.
 - Department approved effluent filter designed to be installed in a four inch diameter tee with extension and installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

A copy of the approved plans and/or specifications is enclosed.

DEL ZOTTO PRODUCTS INC

Page 2

June 2, 2004

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov